

Guide to Heat Requirements

Room Height 2.4m

Room Width (m)	Room Length (m)													
	1	2	3	4	5	6	7	8	9	10	11	12	13	14
1	0.17	0.34	0.51	0.68	0.85	1.02	1.19	1.36	1.53	1.70	1.87	2.04	2.21	2.38
2	0.34	0.68	1.02	1.36	1.70	2.04	2.38	2.72	3.06	3.40	3.74	4.08	4.42	4.76
3	0.51	1.02	1.53	2.04	2.55	3.06	3.57	4.08	4.59	5.10	5.61	6.11	6.62	7.13
4	0.68	1.36	2.04	2.72	3.40	4.08	4.76	5.44	6.11	6.79	7.47	8.15	8.83	9.51
5	0.85	1.70	2.55	3.40	4.25	5.10	5.94	6.79	7.64	8.49	9.34	10.19	11.04	11.89
6	1.02	2.04	3.06	4.08	5.10	6.11	7.13	8.15	9.17	10.19	11.21	12.23	13.25	14.27
7	1.19	2.38	3.57	4.76	5.94	7.13	8.32	9.51	10.70	11.89	13.08	14.27	15.46	16.65
8	1.36	2.72	4.08	5.44	6.79	8.15	9.51	10.87	12.23	13.59	14.95	16.31	17.66	19.02
9	1.53	3.06	4.59	6.11	7.64	9.17	10.70	12.23	13.76	15.29	16.82	18.34	19.87	21.40
10	1.70	3.40	5.10	6.79	8.49	10.19	11.89	13.59	15.29	16.99	18.68	20.38	22.08	23.78
11	1.87	3.74	5.61	7.47	9.34	11.21	13.08	14.95	16.82	18.68	20.55	22.42	24.29	26.16
12	2.04	4.08	6.11	8.15	10.19	12.23	14.27	16.31	18.34	20.38	22.42	24.46	26.50	28.54
13	2.21	4.42	6.62	8.83	11.04	13.25	15.46	17.66	19.87	22.08	24.29	26.50	28.70	30.91
14	2.38	4.76	7.13	9.51	11.89	14.27	16.65	19.02	21.40	23.78	26.16	28.54	30.91	33.29
15	2.55	5.10	7.64	10.19	12.74	15.29	17.83	20.38	22.93	25.48	28.03	30.57	33.12	35.67
16	2.72	5.44	8.15	10.87	13.59	16.31	19.02	21.74	24.46	27.18	29.89	32.61	35.33	38.05
17	2.89	5.77	8.66	11.55	14.44	17.32	20.21	23.10	25.99	28.87	31.76	34.65	37.54	40.42
18	3.06	6.11	9.17	12.23	15.29	18.34	21.40	24.46	27.52	30.57	33.63	36.69	39.75	42.80
19	3.23	6.45	9.68	12.91	16.14	19.36	22.59	25.82	29.04	32.27	35.50	38.73	41.95	45.18
20	3.40	6.79	10.19	13.59	16.99	20.38	23.78	27.18	30.57	33.97	37.37	40.76	44.16	47.56